




INTEGRATED CONTROL, MONITORING AND OPERATION OF POWER DISTRIBUTION TO ENHANCE PRODUCTIVITY




Real-time SCADA System

Supervisory Control And Data Acquisition enables us

- Remotely monitoring of power distribution system and in house generation
- Facilitates supervisory control & operation of devices
- Provides decision support tools to improve the system performance
- Load management through LMS
- Energy consumption reporting through Energy Management system
- Sequence of Event recording to enhance the reliability




System Architecture OverView





SYSTEM CONFIGURATION

Tuesday, May 15, 2007
 2:06:53 PM



Main Menu

Alarm Banner:





SCADA system@BEL is integrated for

- Monitoring and control of Switchgears
- Intelligent auto operation of equipments
- Alarming and protection of the equipments
- Demand side management
- Auto prioritization of loads.
- Auto Starting & Synchronization of captive generation
- Load sharing & Load shedding
- Condition based auto operation
- Auto synchronization
- Remote monitoring and auto operation of substations
- Energy management and Generation of reports.
- Data storage, Trend study and analysis
- Fundamental change in work culture.

LOAD MANAGEMENT SYSTEM

IN HOUSE GENERATION
AND
SYNCHRONISATION



LOAD MANAGEMENT SYSTEM

- Auto starting based on priority
- Auto Synchronization
- Auto loading of diesel generators
- Auto-off loading
- Auto Load sharing of diesel generators
- Auto Load shedding
- Auto shutdown of generators



BHARAT ELECTRONICS LIMITED

LOAD MANAGEMENT SYSTEM

MAIN MENU

PLANT OVERVIEW
DPH

SYNCHRONIZATION

LOAD SHARING

LOAD SHEDDING

COOLING WATER
SYSTEM

COMPRESSOR

GMR RELAY
DATA

LOAD SHEDDING
SUBSTATION

PLANT OVERVIEW
MRS

F1 & F2 SUB STATION-1

F1 & F2 SUB STATION-2

F1 & F2 SUB STATION-3

F3 & F4 SUB STATION-1

F3 & F4 SUB STATION-2

F5 & F6 SUB STATION

S/S BREAKERS
TRIP/NON-TRIP

ANALOG INPUT
INSTANT REPORT

THERMOCOUPLE INPUT
INSTANT REPORT

RTD INPUT
INSTANT REPORT

ENERGY REPORTS

TRENDS

TRENDS S/S

ALARM SUMMARY

SYSTEM CONFIGURATION

LOGOUT




BHARAT ELECTRONICS LIMITED

LOAD MANAGEMENT SYSTEM- Plant Overview

GRID FREQ.	49.31	Hz
GENERATION FREQ.	0.00	Hz

KPTCL GRID
 65157 V
 [66KV, MRS BUS]

TOTAL GRID KVA **7096 kVA**



SYSTEM STATUS

SYSTEM STATUS

Main Menu

10:52:59 A GP POWER MONITOR FAULT

Silence Cntrl F1

- Plant Ovw DPH
- Synchronization
- Load Sharing
- Load Shedding
- Compressor & Chiller
- Cooling Water System
- Auto- Start
- Plant Overview MRS
- Print Cntrl F4

Tag not found: VRS_B1

Clear Clear All



PR CHANGE
OG

BHARAT ELECTRONICS LIMITED

LOAD MANAGEMENT SYSTEM- Auto - Startup/Loading

TOTAL GENERATION kW

TOTAL LOAD ALLOWED kW

TOTAL LOAD kW

GRID FAIL LOAD kW

AUTO OPERATION
TERMINATE

	F1	F2	F3	F4	F5	F6	EF1	EF2	MRS 11KV	CRL 11KV
PRIORITY	<input type="text" value="8"/>	<input type="text" value="7"/>	<input type="text" value="6"/>	<input type="text" value="5"/>	<input type="text" value="9"/>	<input type="text" value="10"/>	<input type="text" value="1"/>	<input type="text" value="2"/>	<input type="text" value="3"/>	<input type="text" value="4"/>
STATUS										
KW	<input type="text" value="1053"/>	<input type="text" value="1473"/>	<input type="text" value="870"/>	<input type="text" value="762"/>	<input type="text" value="1131"/>	<input type="text" value="774"/>	<input type="text" value="111"/>	<input type="text" value="228"/>	<input type="text" value="291"/>	<input type="text" value="213"/>
MAX KW	<input type="text" value="450"/>	<input type="text" value="250"/>	<input type="text" value="300"/>	<input type="text" value="350"/>	<input type="text" value="300"/>	<input type="text" value="300"/>	<input type="text" value="140"/>	<input type="text" value="240"/>	<input type="text" value="280"/>	<input type="text" value="50"/>

	MMB1	MMB2	MMB3	MB	PB1	PB2	PB3	PB4
PRIORITY	<input type="text" value="1"/>	<input type="text" value="2"/>	<input type="text" value="3"/>	<input type="text" value="7"/>	<input type="text" value="4"/>	<input type="text" value="5"/>	<input type="text" value="6"/>	<input type="text" value="0"/>
DG STATUS								
BREAKER STS								
OPER FAIL	<input type="text" value="0"/> kW	<input type="text" value="0"/> kW	<input type="text" value="0"/> kW	<input type="text" value="0"/> kW	<input type="text" value="0"/> kW	<input type="text" value="0"/> kW	<input type="text" value="0"/> kW	<input type="text" value="0"/> kW
	<input type="text" value="0.00"/> PF	<input type="text" value="0.00"/> PF	<input type="text" value="0.00"/> PF	<input type="text" value="0.00"/> PF	<input type="text" value="0.01"/> PF	<input type="text" value="0.00"/> PF	<input type="text" value="-0.01"/> PF	<input type="text" value="0.00"/> PF

Main Menu

Plant Ovw

10:52:59 A GP POWER MONITOR FAULT

Silence Cntrl F1

Print Cntrl F4

Trends

Load Sharing

Load Shedding

Analog

Thermocouple

RTD

Plant Overview MRS

Compressor & Chiller

Cooling Water System

Tag not found: VRS_B1

Clear Clear All



BHARAT ELECTRONICS LIMITED
LOAD MANAGEMENT SYSTEM- Load Sharing

MMB#1 Priority- 1
 Mode of Operation
 Load Sharing LOCAL REMOTE
 Off AUTO MANUAL
 kW kVAR
 0.0 0.0
 kW Setpoint kVAR Setpoint
 50 75
 Capacity kW Capacity kVAR
 2000 1650
 PF Voltage (v)
 0.00 0.0
G

MMB#2 Priority- 2
 Mode of Operation
 Load Sharing LOCAL REMOTE
 Off AUTO MANUAL
 kW kVAR
 0.0 0.0
 kW Setpoint kVAR Setpoint
 50 75
 Capacity kW Capacity kVAR
 1400 1350
 PF Voltage (v)
 0.00 0.0
G

MMB#3 Priority- 3
 Mode of Operation
 Load Sharing LOCAL REMOTE
 Off AUTO MANUAL
 kW kVAR
 0.0 0.0
 kW Setpoint kVAR Setpoint
 50 75
 Capacity kW Capacity kVAR
 1400 1350
 PF Voltage (v)
 0.00 0.0
G

MB Priority- 7
 Mode of Operation
 Load Sharing LOCAL REMOTE
 Off AUTO MANUAL
 kW kVAR
 0.0 0.0
 kW Setpoint kVAR Setpoint
 50 75
 Capacity kW Capacity kVAR
 1200 900
 PF Voltage (v)
 0.00 0.0
G

PB#1 Priority- 4
 Mode of Operation
 Load Sharing LOCAL REMOTE
 Off AUTO MANUAL
 kW kVAR
 0.0 0.0
 kW Setpoint kVAR Setpoint
 25 75
 Capacity kW Capacity kVAR
 650 487
 PF Voltage (v)
 0.07 11134.5
G

PB#2 Priority- 5
 Mode of Operation
 Load Sharing LOCAL REMOTE
 Off AUTO MANUAL
 kW kVAR
 0.0 0.0
 kW Setpoint kVAR Setpoint
 25 75
 Capacity kW Capacity kVAR
 650 487
 PF Voltage (v)
 0.00 0.0
G

PB#3 Priority- 6
 Mode of Operation
 Load Sharing LOCAL REMOTE
 Off AUTO MANUAL
 kW kVAR
 0.0 0.0
 kW Setpoint kVAR Setpoint
 25 75
 Capacity kW Capacity kVAR
 650 487
 PF Voltage (v)
 -0.0 11128.7
G

PB#4 Priority- 0
 Mode of Operation
 Load Sharing LOCAL REMOTE
 Off AUTO MANUAL
 kW kVAR
 0.0 0.0
 kW Setpoint kVAR Setpoint
 500 75
 Capacity kW Capacity kVAR
 650 487
 PF Voltage (v)
 0.00 0.0
G

Freq. Setpoint (Hz): **50.00**

Volt. Setpoint (v): **11000**



BHARAT ELECTRONICS LIMITED
LOAD MANAGEMENT SYSTEM- Synchronization

CASE SELECTION

- 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21

MODE

Live Bus



Vol. Error 0.00 %
 Freq. Error 0.00 Hz
 Phase Error 0 deg

Synchronisation Off

Reference Bus Parameters

Line Voltage R - Y 0 V
 Line Voltage Y - B 0 V
 Line Voltage B - R 0 V
 Average Line Voltage 0 V
 Phase Voltage R 0 V
 Phase Voltage Y 0 V
 Phase Voltage B 0 V
 Average Phase Voltage 0 V
 Frequency 0.00 Hz
 Phase Rotation RBY

Synchronising Bus Parameters

Line Voltage R - Y 0 V
 Line Voltage Y - B 0 V
 Line Voltage B - R 0 V
 Average Line Voltage 0 V
 Phase Voltage R 0 V
 Phase Voltage Y 0 V
 Phase Voltage B 0 V
 Average Phase Voltage 0 V
 Frequency 0.00 Hz
 Phase Rotation RBY

MMB-1	0.00 Kw	PB-1	0.00 Kw
MMB-2	0.00 Kw	PB-2	0.00 Kw
MMB-3	0.00 Kw	PB-3	0.00 Kw
MB	0.00 Kw	PB-4	0.00 Kw

Main Menu

10:52:59 A GP POWER MONITOR FAULT

Silence Cntrl F1

Print Cntrl F4

Plant Ovw

Synchronization:

Trends

Load Sharing

Load Shedding

Analog

Thermocouple

RTD

Plant Overview MRS

Compressor & Chiller

Cooling Water System

Tag not found: VRS_B1

Clear

Clear All



BHARAT ELECTRONICS LIMITED

LOAD MANAGEMENT SYSTEM- Load Shedding Report

DT. 09 / 01 / 2006

REASON: GRID-2 TRIPPED

TIME 18 : 52 : 56


PRT	FEEDER DESCRIPTION	STATUS	LOAD (KW)	LS Command
01	OUTGOING F6 FEEDER	OFF	0	NO
02	OUTGOING F5 FEEDER	OFF	0	NO
03	OUTGOING F1 FEEDER	OFF	0	NO
04	OUTGOING F2 FEEDER	OFF	0	NO
05	OUTGOING F3 FEEDER	OFF	0	NO
06	OUTGOING F4 FEEDER	OFF	0	NO
07	OUTGOING CRL FEEDER	OFF	0	NO
08	OUTGOING MRS FEEDER	OFF	0	NO
09	OUTGOING EF2 FEEDER	OFF	0	NO
10	OUTGOING EF1 FEEDER	OFF	0	NO

	KW
MMB-1	0
MMB-2	0
MMB-3	0
MB	0
PB-1	0
PB-2	0
PB-3	0
PB-4	0
GRID-1	1106
GRID-2	0
GRID-3	2325

LOAD TO BE SHED (KW)	LOAD SHED (KW)
0	0



BHARAT ELECTRONICS LIMITED
LOAD MANAGEMENT SYSTEM- Compressor & Chiller




Main Menu	10:52:59 A	GP POWER MONITOR FAULT				Silence Cntrl F1	Print Cntrl F4		
Plant Ovvr	Synchronization	Trends	Load Sharing	Load Shedding	Analog	Thermocouple	Plant Overview MRS	Compressor & Chiller	Cooling Water System

Tag not found: VRS_B1

Clear Clear All



BHARAT ELECTRONICS LIMITED
LOAD MANAGEMENT SYSTEM- CW SYSTEM



Main Menu 10:52:59 A GP POWER MONITOR FAULT Silence Cntrl F1 Print Cntrl F4

Plant Ovw Synchronization Trends Load Sharing Load Shedding Analog **Thermocouple** RTD Plant Overview MRS **Compressor & Chiller** Cooling Water System

Tag not found: VRS_B1 Clear Clear All



LOAD MANAGEMENT SYSTEM- RTD Input Instant Report

Main
Menu



Print
Cntrl F4



Monday, January 23, 2006 11:51:37 AM

MMB1 CHARGE AIR TEMP.	29.3	DEG. C.
MMB2 CHARGE AIR TEMP.	36.8	DEG. C.
MMB3 CHARGE AIR TEMP.	36.3	DEG. C.
MB BEARING TEMP.	22.7	DEG. C.
MB BEARING LUB OIL TEMP.	23.9	DEG. C.
MB LUB OIL TEMP.	22.4	DEG. C.
MB CLR LO O/L TEMP.	22.5	DEG. C.
MB JCKT WATER IL TEMP.	22.6	DEG. C.
MB JCKT WATER O/L TEMP.	22.6	DEG. C.
MB EXHAUST TEMP. -A1	26.0	DEG. C.
MB EXHAUST TEMP. -A2	23.6	DEG. C.
MB EXHAUST TEMP. -A3	25.0	DEG. C.
MB EXHAUST TEMP. -A4	25.9	DEG. C.
MB EXHUAST TEMP. -A5	25.4	DEG. C.
MB EXHAUST TEMP. -A6	24.9	DEG. C.
MB EXHAUST TEMP. -B1	23.5	DEG. C.
MB EXHAUST TEMP. -B2	25.3	DEG. C.
MB EXHAUST TEMP. -B3	25.7	DEG. C.
MB EXHAUST TEMP. -B4	26.2	DEG. C.
MB EXHAUST TEMP. -B5	27.6	DEG. C.
MB EXHAUST TEMP. -B6	26.2	DEG. C.
MB EXHUAST TEMP. -AT	24.5	DEG. C.
MB RW IL TEMP.	22.3	DEG. C.
MB RW O/L TEMP.	22.4	DEG. C.
MB HEAT EXCH O/L TEMP.	22.5	DEG. C.
MB CHARGE AIR TEMP.	23.0	DEG. C.

PB1 COOLANT TEMP.	22.2	DEG. C.
PB1 EXHAUST TEMP. -1	24.1	DEG. C.
PB1 EXHAUST TEMP. -2	24.1	DEG. C.
PB1 LUBE OIL TEMP.	22.0	DEG. C.
PB1 RW IL TEMP.	22.5	DEG. C.
PB1 RW O/L TEMP.	870.0	DEG. C.
PB2 COOLANT TEMP.	22.0	DEG. C.
PB2 EXHAUST TEMP. -1	23.8	DEG. C.
PB2 EXHAUST TEMP. -2	24.2	DEG. C.
PB2 LUBE OIL TEMP.	21.6	DEG. C.
PB2 RW IL TEMP.	21.7	DEG. C.
PB3 COOLANT TEMP.	21.7	DEG. C.
PB3 EXHAUST TEMP. -1	24.2	DEG. C.
PB3 EXHAUST TEMP. -2	24.0	DEG. C.
PB3 LUBE OIL TEMP.	21.7	DEG. C.
PB3 RW IL TEMP.	21.7	DEG. C.
PB4 COOLANT TEMP.	53.9	DEG. C.
PB4 EXHAUST TEMP. -1	23.8	DEG. C.
PB4 EXHAUST TEMP. -2	24.3	DEG. C.
PB4 LUBE OIL TEMP.	20.8	DEG. C.
PB4 RW IL TEMP.	22.5	DEG. C.
50KL SUMP RW TEMP.	870.0	DEG. C.



LOAD MANAGEMENT SYSTEM- Thermo-Couple Input Instant Report

Monday, January 23, 2006 11:50:33 AM

Main Menu



Print Cntrl F4



MMB-1

EXHAUST TEMP. -A1	39.5	DEG. C.
EXHAUST TEMP. -A2	41.0	DEG. C.
EXHAUST TEMP. -A3	41.8	DEG. C.
EXHAUST TEMP. -A4	42.7	DEG. C.
EXHAUST TEMP. -A5	42.8	DEG. C.
EXHAUST TEMP. -A6	38.0	DEG. C.
EXHAUST TEMP. -A7	41.9	DEG. C.
EXHAUST TEMP. -A8	41.6	DEG. C.
EXHAUST TEMP. -B1	40.4	DEG. C.
EXHAUST TEMP. -B2	40.3	DEG. C.
EXHAUST TEMP. -B3	40.7	DEG. C.
EXHAUST TEMP. -B4	41.2	DEG. C.
EXHAUST TEMP. -B5	41.4	DEG. C.
EXHAUST TEMP. -B6	41.0	DEG. C.
EXHAUST TEMP. -B7	40.4	DEG. C.
EXHAUST TEMP. -B8	39.7	DEG. C.
EXHAUST TEMP. -AT	31.8	DEG. C.

MMB-2


EXHAUST TEMP. -A1	40.5	DEG. C.
EXHAUST TEMP. -A2	42.2	DEG. C.
EXHAUST TEMP. -A3	42.6	DEG. C.
EXHAUST TEMP. -A4	42.6	DEG. C.
EXHAUST TEMP. -A5	41.9	DEG. C.
EXHAUST TEMP. -A6	43.7	DEG. C.
EXHAUST TEMP. -B1	42.3	DEG. C.
EXHAUST TEMP. -B2	42.8	DEG. C.
EXHAUST TEMP. -B3	43.5	DEG. C.
EXHAUST TEMP. -B4	43.1	DEG. C.
EXHAUST TEMP. -B5	43.5	DEG. C.
EXHAUST TEMP. -B6	44.6	DEG. C.
EXHAUST TEMP. -AT	29.4	DEG. C.


MMB-3

EXHAUST TEMP. -A1	9.0	DEG. C.
EXHAUST TEMP. -A2	41.8	DEG. C.
EXHAUST TEMP. -A3	41.0	DEG. C.
EXHAUST TEMP. -A4	41.0	DEG. C.
EXHAUST TEMP. -A5	40.7	DEG. C.
EXHAUST TEMP. -A6	39.8	DEG. C.
EXHAUST TEMP. -B1	38.7	DEG. C.
EXHAUST TEMP. -B2	40.4	DEG. C.
EXHAUST TEMP. -B3	41.2	DEG. C.
EXHAUST TEMP. -B4	42.2	DEG. C.
EXHAUST TEMP. -B5	41.9	DEG. C.
EXHAUST TEMP. -B6	41.5	DEG. C.
EXHAUST TEMP. -AT	29.0	DEG. C.



LOAD MANAGEMENT SYSTEM- Analog Input Instant Report

Main Menu 

Print Cntrl F4 

Monday, January 23, 2006 11:43:38 AM

MMB1 FO PR. BEFORE FILTER	1.12	bar
MMB1 FO PR. AFTER FILTER	0.36	bar
MMB1 LO PR. BEFORE FILTER	0.06	bar
MMB1 LO PR. AFTER FILTER	0.00	bar
MMB1 JACKET WATER PR.	0.00	bar
MMB1 CHARGE AIR PR.	0.00	bar
MMB1 RW INLET PR.	0.00	bar
MMB1 RW OUTLET PR.	0.11	bar
MMB1 AIR BOTTLE PR.	24.89	bar
MMB2 FO PR. BEFORE FILTER	1.81	bar
MMB2 FO PR. AFTER FILTER	4.25	bar
MMB2 LO PR. BEFORE FILTER	0.02	bar
MMB2 LO PR. AFTER FILTER	0.02	bar
MMB2 JACKET WATER PR.	0.26	bar
MMB2 CHARGE AIR PR.	0.00	bar
MMB2 RW INLET PR.	0.24	bar
MMB2 RW OUTLET PR.	0.11	bar
MMB2 AIR BOTTLE PR.	23.80	bar
MMB3 FO PR. BEFORE FILTER	0.00	bar
MMB3 FO PR. AFTER FILTER	0.00	bar
MMB3 LO PR. BEFORE FILTER	0.06	bar
MMB3 LO PR. AFTER FILTER	0.04	bar
MMB3 JACKET WATER PR.	0.00	bar
MMB3 CHARGE AIR PR.	0.01	bar
MMB3 RW INLET PR.	0.23	bar
MMB3 RW OUTLET PR.	0.10	bar
MMB3 AIR BOTTLE PR.	23.80	bar

MB BEARING OIL INLET PR.	0.01	bar
MB LUB OIL PR.	0.06	bar
MB JACKET WATER PR.	0.31	bar
MB COOLER PR.	0.13	bar
MB BOOST AIR PR.	0.01	bar
MB RAW WATER INLET PR.	0.21	bar
MB RAW WATER OUTLET PR.	0.15	bar
MB AIR BOTTLE PR.	23.99	bar
PB1 RW INLET PR.	0.17	bar
PB1 RW OUTLET PR.	0.17	bar
PB1 LO PR.	0.00	bar
PB1 COOLANT PR.	0.04	bar
PB2 RW INLET PR.	0.17	bar
PB2 RW OUTLET PR.	0.18	bar
PB2 LO PR.	0.03	bar
PB2 COOLANT PR.	0.05	bar
PB3 RW INLET PR.	0.20	bar
PB3 RW OUTLET PR.	0.18	bar
PB3 LO PR.	0.00	bar
PB3 COOLANT PR.	0.06	bar
PB4 RW INLET PR.	0.00	bar
PB4 RW OUTLET PR.	0.00	bar
PB4 LO PR.	0.00	bar
PB4 COOLANT PR.	0.00	bar

SEC CW SUMP LEVEL	0.0	%
FO SYSTEM TANK 1 LEVEL	7147.9	L
FO SYSTEM TANK 2 LEVEL	7740.3	L
FO 200KL TANK 1 LEVEL	46.3	KL
TOTAL FUEL QUANTITY	61.2	KL
24 V DC BATT. CHARGER 1	0.0	V
24 V DC BATT. CHARGER 2	0.0	V
OLTC 1 TAP POSITION	0.0	
OLTC 2 TAP POSITION	0.0	
OLTC 3 TAP POSITION	0.0	

REDUCTION IN MAN POWER REQUIREMENT

**SUPERVISORY CONTROL AND REMOTE OPERATION
OF
Central Main Receiving Station and SUBSTATIONS at
different locations in the factory**

- ❖ Centralized monitoring of all the 18 substations spread across the factory leads to reduction in man power requirement for deploying skilled labour at all substations




BHARAT ELECTRONICS LIMITED
LOAD MANAGEMENT SYSTEM-Plant Overview MRS

GRID FREQ. 49.31 Hz
 GENERATION FREQ. 0.00 Hz



KPTCL GRID
 65053 V
 [66KV, MRS BUS]

TOTAL GRID KW 6872 kW
 TOTAL GRID KVA 7175 kVA



TOTAL GENERATION kW 0 kW
 TOTAL GENERATION KVA 0 kVA
 TOTAL LOAD kW 6814 kW
 TOTAL LOAD KVA 7175 kVA
 ENERGY METER 49751 kwh

kW	1149	114	774	840	705	213	1065	231	280	1443
PF	-0.95	-0.95	-0.98	-0.97	-0.89	0.86	-0.97	0.99	0.92	0.97
kWh	7695	1291	5416	6117	7941	1211	8030	2106	2325	7614

Main Menu 10:52:59 A GP POWER MONITOR FAULT Silence Cntrl F1 Print Cntrl F4

Plant Ovw DPH Synchronization Load Sharing Load Shedding F1 & F2 Substation-1 F1 & F2 Substation-2 F1 & F2 Substation-3 F3 & F4 Substation-1 F3 & F4 Substation-2 F5 & F6 Substation Auto-Start

Tag not found: VRS_B1




TOTAL LOAD
 6817 kW

BHARAT ELECTRONICS LIMITED
LOAD MANAGEMENT SYSTEM- SUB-STATIONS

F1 & F2 SCREEN - 1

EXIT



- F1 & F2 SCREEN - 1
- F1 & F2 SCREEN - 2
- F1 & F2 SCREEN - 3
- F3 & F4 SCREEN - 1
- F3 & F4 SCREEN - 2
- F5 & F6

Main Menu 10:52:59 A **GP POWER MONITOR FAULT**

Plant Ovw Synchronization Trends Load Sharing Load Shedding Analog Thermocouple RTD Plant Overview MRS Compressor & Chiller Cooling Water System

Silence Cntrl F1 Print Cntrl F4

Tag not found: VRS_B1 Clear All




TOTAL LOAD
 6834 kW

BHARAT ELECTRONICS LIMITED
LOAD MANAGEMENT SYSTEM- SUB-STATIONS

F1 & F2 SCREEN - 2

EXIT



- F1 & F2 SCREEN - 1
- F1 & F2 SCREEN - 2
- F1 & F2 SCREEN - 3
- F3 & F4 SCREEN - 1
- F3 & F4 SCREEN - 2
- F5 & F6

Main Menu 10:52:59 A **GP POWER MONITOR FAULT** Silence Cntrl F1 Print Cntrl F4

Plant Ovw Synchronization Trends Load Sharing Load Shedding Analog Thermocouple RTD Plant Overview MRS Compressor & Chiller Cooling Water System

Tag not found: VRS_B1

Clear All



BHARAT ELECTRONICS LIMITED
LOAD MANAGEMENT SYSTEM- Auto - Startup/Loading

PR CHANGE
 OG

TOTAL GENERATION kW

TOTAL LOAD ALLOWED kW

TOTAL LOAD kW

GRID FAIL LOAD kW

**AUTO OPERATION
 TERMINATE**

	F1	F2	F3	F4	F5	F6	EF1	EF2	MRS 11KV	CRL 11KV
PRIORITY	<input type="text" value="8"/>	<input type="text" value="7"/>	<input type="text" value="6"/>	<input type="text" value="5"/>	<input type="text" value="9"/>	<input type="text" value="10"/>	<input type="text" value="1"/>	<input type="text" value="2"/>	<input type="text" value="3"/>	<input type="text" value="4"/>
STATUS										
KW	<input type="text" value="1053"/>	<input type="text" value="1473"/>	<input type="text" value="870"/>	<input type="text" value="762"/>	<input type="text" value="1131"/>	<input type="text" value="774"/>	<input type="text" value="111"/>	<input type="text" value="228"/>	<input type="text" value="291"/>	<input type="text" value="213"/>
MAX KW	<input type="text" value="450"/>	<input type="text" value="250"/>	<input type="text" value="300"/>	<input type="text" value="350"/>	<input type="text" value="300"/>	<input type="text" value="300"/>	<input type="text" value="140"/>	<input type="text" value="240"/>	<input type="text" value="280"/>	<input type="text" value="50"/>

	MMB1	MMB2	MMB3	MB	PB1	PB2	PB3	PB4
PRIORITY	<input type="text" value="1"/>	<input type="text" value="2"/>	<input type="text" value="3"/>	<input type="text" value="7"/>	<input type="text" value="4"/>	<input type="text" value="5"/>	<input type="text" value="6"/>	<input type="text" value="0"/>
DG STATUS								
BREAKER STS								
OPER FAIL	<input type="text" value="0"/> kW <input type="text" value="0.00"/> PF	<input type="text" value="0"/> kW <input type="text" value="0.00"/> PF	<input type="text" value="0"/> kW <input type="text" value="0.00"/> PF	<input type="text" value="0"/> kW <input type="text" value="0.00"/> PF	<input type="text" value="0"/> kW <input type="text" value="0.01"/> PF	<input type="text" value="0"/> kW <input type="text" value="0.00"/> PF	<input type="text" value="0"/> kW <input type="text" value="-0.01"/> PF	<input type="text" value="0"/> kW <input type="text" value="0.00"/> PF

Main Menu **10:52:59 A GP POWER MONITOR FAULT** Silence Cntrl F1 Print Cntrl F4

Plant Ovw Synchronization Trends Load Sharing Load Shedding Analog Thermocouple RTD Plant Overview MRS Compressor & Chiller Cooling Water System

Tag not found: VRS_B1

SAFETY AND STABILITY IN OPERATION

INTERLOCKS AND SEQUENTIAL LOGIC

SOFTWARE INTERLOCKS



MRS BC-2

MRS BUSCOUPLER-2

CLOSE **OPEN**

BREAKER IN OPEN POSITION

BREAKER TRIP CIRCUIT HEALTHY

BREAKER SPRING CHARGED

BREAKER SEL. SWITCH IN REMOTE POS.

RESET

ELECTRONICS LIMITED


ALARM

CLOSING OF THIS BUS COUPLER IS NOT ALLOWED

PARALLALING OF TRANSFORMERS IS NOT ALLOWED THROUGH SCADA*

kW **6686 kW**

kVA **6969 kVA**




Main Menu **10:52:59 A** **GP POWER MONITOR FAULT** Silence Cntrl F1 Print Cntrl F4

Plant Ovw DPH Synchronization Load Sharing Load Shedding F1 & F2 Substation-1 F1 & F2 Substation-2 F1 & F2 Substation-3 F3 & F4 Substation-1 F3 & F4 Substation-2 F5 & F6 Substation Auto-Start

Tag not found: VRS_B1

Clear Clear All



GRID [Close] [Maximize] [Minimize]


GRID SYNCHRONIZATION
 Paralleling of Transformers is NOT Permitted

Reverse Synchronization is NOT Allowed by DPH Section

300 GRID KW SETPOINT

GRID SYNCHRONIZATION TERMINATE

BHARAT ELECTRONICS LIMITED
 T SYSTEM-Plant Overview MRS



Main Menu [Home] **10:52:59 A GP POWER MONITOR FAULT** Silence Cntrl F1 [Speaker] Print Cntrl F4 [Printer]

Plant Ovw DPH Synchronization Load Sharing Load Shedding F1 & F2 Substation-1 F1 & F2 Substation-2 F1 & F2 Substation-3 F3 & F4 Substation-1 F3 & F4 Substation-2 F5 & F6 Substation Auto-Start

Tag not found: VRS_B1 [Clear] [Clear All]



BHARAT ELECTRONICS LIMITED
SYSTEM-SUB-STATIONS

F3 & F4 SCREEN - 2

BREAKER INTERLOCK

HARDWARE INTERLOCKS EXISTING AT SUBSTATION.



CLOSING OF THIS BREAKER IS NOT ALLOWED !!

HF 11KV BC

CLOSE **OPEN**

BREAKER IN OPEN POSITION
BREAKER TRIP FEEDBACK EXISTS

SD 415V BC



REMOTE I/O PANEL STATUS OK REMOTE I/O PANEL STATUS OK REMOTE I/O PANEL STATUS OK

F1 & F2 SCREEN - 1 F1 & F2 SCREEN - 2 F1 & F2 SCREEN - 3 F3 & F4 SCREEN - 1 F3 & F4 SCREEN - 2 F5 & F6

Main Menu 11:14:29 A GP 415V INCOMER-2 OPENED Silence Cntrl F1 Print Cntrl F4

Plant Overview Compressor Cooling Water

OPC ERROR - '(RSLinx Remo~ OPC Server) Server: The Item is no longer available.'

ENERGY MANAGEMENT SYSTEM

TRENDS AND DATABASE



Trends To Monitor Online and Control

- Study of load patterns
- Load balancing /sharing
- Maintain good voltage / frequency profile
- Power factor management
- Maximum demand analysis and control
- Optimize and monitor to achieve cost reduction and equipment safety
- Better information for engineering and planning




BHARAT ELECTRONICS LIMITED

Trend

Power Management System Monday, July 25, 2005

12:33:05 PM

- BKR\OG_EF1\LOAD
- BKR\OG_EF2\LOAD
- BKR\OG_F1\LOAD
- BKR\OG_F2\LOAD
- BKR\OG_F3\LOAD
- BKR\OG_F4\LOAD
- BKR\OG_F5\LOAD
- BKR\OG_F6\LOAD
- BKR\OG_MRS_11KV\LOAD



12:03:05 PM 12:33:05 PM

Main Menu

Silence Cntrl F1 Print Cntrl F4

- Plant Ovvr
- Synchronization
- Trends
- Load Sharing
- Load Shedding
- Analog
- Thermocouple
- RTD
- Plant Overview MRS
- Compressor & Chiller
- Cooling Water System

Clear Clear All



BHARAT ELECTRONICS LIMITED
LOAD MANAGEMENT SYSTEM - Power monitor

OG F5

	<i>VOLTAGE</i>	
<i>R - N</i>	<input type="text" value="6256.0"/>	VOLT
<i>Y - N</i>	<input type="text" value="6375.9"/>	VOLT
<i>B - N</i>	<input type="text" value="6276.0"/>	VOLT
<i>AVERAGE</i>	<input type="text" value="6302.7"/>	VOLT
<i>R - Y</i>	<input type="text" value="10842.3"/>	VOLT
<i>Y - B</i>	<input type="text" value="11050.2"/>	VOLT
<i>B - R</i>	<input type="text" value="10877.0"/>	VOLT
<i>AVERAGE</i>	<input type="text" value="10923.1"/>	VOLT

	<i>CURRENT</i>		<i>ACTIVE POWER</i>		<i>REACTIVE POWER</i>		<i>APARENT POWER</i>	
<i>R - N</i>	<input type="text" value="60.6"/>	AMP	<input type="text" value="366.0"/>	KW	<input type="text" value="132.8"/>	KVAR	<input type="text" value="379.1"/>	KVA
<i>Y - N</i>	<input type="text" value="67.2"/>	AMP	<input type="text" value="411.0"/>	KW	<input type="text" value="83.5"/>	KVAR	<input type="text" value="428.5"/>	KVA
<i>B - N</i>	<input type="text" value="63.9"/>	AMP	<input type="text" value="393.0"/>	KW	<input type="text" value="129.2"/>	KVAR	<input type="text" value="401.0"/>	KVA
<i>TOTAL</i>			<input type="text" value="1170.0"/>	KW	<input type="text" value="351.2"/>	KVAR	<input type="text" value="1208.6"/>	KVA

<i>POWER FACTOR</i>
<input type="text" value="-0.957"/>

Plant Overview
MRS

Plant Overview
DPH



Reporting and Data Base

- Online metering of energy consumption
- Online hourly logging
- Daily/monthly/yearly energy consumption reports
- Load survey and energy accounting
- Identification of high consumption area for optimization of energy consumption.



Customer information management

- Information to customers is managed through e-mails regarding monthly energy consumption and preventive maintenance schedules

Integration to SAP/MRP system

- The reports generation tool is integrated to our SAP system enabling online data access to the customers



BHARAT ELECTRONICS LIMITED

LOAD MANAGEMENT SYSTEM

MAIN MENU

PLANT OF DE

SYNCHRO

LOAD SH

LOAD SH

COOLING SYST

COMPE

GMR F DA

LOAD SH SUBST

TIME SYNCH

LOG INPUT ANT REPORT

DCOUPLE INPUT ANT REPORT

TD INPUT ANT REPORT

GY REPORTS

TRENDS

RENDS S/S

M SUMMARY

CONFIGURATION

LOGOUT

BEL Reports

Select Report Type

- Rec. Station Log Sheet
- Load in KW
- Energy Consumption
- Peak Load Report
- Energy Mgmt. Report
- DG LogSheet Report

Select Category

- Daily Report
- Monthly Report
- Yearly Report

Available Dates

15-May-2007
 14-May-2007
 13-May-2007
 12-May-2007
 11-May-2007
 10-May-2007
 09-May-2007
 08-May-2007
 07-May-2007
 06-May-2007
 05-May-2007
 04-May-2007

For Date

Show

Close



SEQUENCE OF EVENT RECORDING



BENEFITS

- Enables online measurement of electrical and DG parameters , resulting in optimization of process control on the basis of dynamic, accurate system / plant overview.
- Advanced monitoring, control and operation thro' automatic data recording and logging.
- Load sharing, Load shedding and Demand management
- Energy accounting and feed back to individual user
- Loss measurement at interfaces
- Suitably customized to meet the individual departmental needs and aligned to the business objectives by reducing cost of operation, improving efficiency.

Case study on Military Radar SBU

- One of the major productive SBUs



Turnover of BEL, Bangalore Complex for the year 2011-12 → **Rs. 3704 crores**

Turnover of MR SBU → **Rs. 765 crores**



Power supply for all the critical manufacturing process/acceptance tests of MR SBU is controlled and monitored from central station, situated about a KM from the load centre. The processes includes environmental tests and endurance tests which run for 3-5 days continuously, needs high attention towards the facility management to avoid failure during the process. Continuous power supply is an essence during the period/inspection by Defence inspection team. Hence Radar substation is always kept at highest priority for loading on DG sets in case of power failure. Also continuous monitoring of load patterns are done through trends.



If any fault / failures occurs disturbing the process, the fault records are displayed in the system through pop up messages at Central station enabling for rectification with minimum down time thereby avoiding impact on production processes.

Financial LOSS estimated due to delay in resumption/ failure due to poor monitoring at MR SBU is around Rs. 8.7 lakhs per hour in the single division alone.



COST REDUCTION

- Significant energy savings is achieved through continuous energy monitoring which has lead financial savings for the company.
- Energy savings achieved during the financial year 2011-12 is 15.25 lakh units.

THANK YOU

